



ARKANSAS
Department of Environmental Quality

February 23, 2017

David Sartain, Envir. Manager
El Dorado Chemical
P.O. Box 231
El Dorado, AR 71730

Email <dsartain@edc-ark.com>

RE: NPDES Permit Number AR0000752, AFIN 70-00040
NPDES Permit Effluent Violations

Dear Mr. Sartain,

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violations of the effluent limitations in Part I, Section A of your Permit for the reporting periods ending December 31, 2016 and January 31, 2017.

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
01/31/2017	006-A	Zinc, total recoverable, MO AVG, ug/L	115.62	330	185%
01/31/2017	006-A	Zinc, total recoverable, DAILY MX, ug/L	231.99	300	29%
01/31/2017	006-A	Lead, total recoverable, MO AVG, ug/L	3.8	19	400%
01/31/2017	007-A	Lead, total recoverable, MO AVG, ug/L	3.8	9	137%
01/31/2017	006-A	Lead, total recoverable, DAILY MX, ug/L	7.62	19	149%
01/31/2017	007-A	Lead, total recoverable, DAILY MX, ug/L	7.62	9	18%
12/31/2016	006-A	Zinc, total recoverable, MO AVG, ug/L	115.62	220	90%
12/31/2016	006-A	Lead, total recoverable, MO AVG, ug/L	3.8	6.6	74%
12/31/2016	007-A	Lead, total recoverable, MO AVG, ug/L	3.8	6.6	74%
12/31/2016	007-A	Solids, total dissolved, MO AVG, mg/L	291	300	3%

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or you may e-mail me at pemberton@adeq.state.ar.us.

Sincerely,

A handwritten signature in black ink, reading "Layne Pemberton". The signature is written in a cursive style with a long horizontal flourish extending to the right.

Layne Pemberton
Enforcement Analyst
Office of Water Quality
NPDES Enforcement Section