



August 8, 2018

David Sartain, Envir. Manager
El Dorado Chemical
P.O. Box 231
El Dorado, AR 71730

Email: dsartain@edc-ark.com

RE: NPDES Permit Number AR0000752, AFIN 70-00040
NPDES Permit Effluent Violations

Dear Mr. Withrow,

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violations of the effluent limitations in Part I, Section A of your Permit for the following reporting periods.

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
06/30/2018	010-A	Solids, total suspended, DAILY MX, lb/d	750.6	862.42	15%

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or you may e-mail me at pemberton@adeq.state.ar.us.

Sincerely,

Layne Pemberton
Enforcement Analyst
NPDES Enforcement Section, Office of Water Quality