



March 13, 2019

David Sartain, Envir. Manager
El Dorado Chemical
P.O. Box 231
El Dorado, AR 71730

Email: dsartain@edc-ark.com

RE: NPDES Permit Number AR0000752, AFIN 70-00040
NPDES Permit Effluent Violations

Dear Mr. Dartain,

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violations of the effluent limitations in Part I, Section A of your Permit for the following reporting periods.

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
01/31/2019	010-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	265.2	369.88	39%	E90	00610-1-0
01/31/2019	010-A	Nitrogen, ammonia total [as N], DAILY MX, lb/d	605	705.81	17%	E90	00610-1-0
01/31/2019	010-A	Nitrogen, nitrate total [as N], MO AVG, lb/d	581.3	778.41	34%	E90	00620-1-0
12/31/2018	010-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	265.2	447.85	69%	E90	00610-1-0
12/31/2018	010-A	Nitrogen, ammonia total [as N], DAILY MX, lb/d	605	717.91	19%	E90	00610-1-0
12/31/2018	010-A	Nitrogen, nitrate total [as N], MO AVG, lb/d	581.3	831.42	43%	E90	00620-1-0

Any violation of your Permit is subject to further enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or you may e-mail me at pemberton@adeq.state.ar.us.

Sincerely,

Layne Pemberton
Enforcement Analyst
NPDES Enforcement Section, Office of Water Quality