## NPDES Permit No. AR0000752 El Dorado Chemical Company Outfall 003 Non-Compliance Report March 2023

All parameters sampled at 003 were within permit limits except for the following:

Parameter	Date	Permit Limit	Sample Result
Coliform, fecal general 30 day geometric	3/1/23-3/31/23	1000 colonies/100ml	1295 colonies/100ml
Solids, total suspended Loading Monthly average	3/1/23-3/31/23	2.1 lbs./day	3.19 lbs./day

Quarterly samples for outfall 003 were taken on March 13, 2023. Efforts, such as adding Ridx and chlorine tablets, were taken to lower the concentrations but were not successful in sufficiently treating the water for coliform. We are continuing our efforts at a more frequent rate now. The concentration for Total Suspended Solids was below the detection or reporting limit of 10 mg/l. When calculating the loading using 10 mg/l, we surpassed the permit limit due to increased flow from several rain events.