

**NPDES Permit No.  
AR0000752  
El Dorado Chemical Company  
Outfalls 006 and 007  
Non-Compliance Report  
December 2022**

<b>Parameter</b>	<b>Date</b>	<b>Permit Limit</b>	<b>Reported Value</b>
Streamflow- Downstream Monitoring Monthly average	12/14/22-12/31/22	Report	0.1201 MGD
Streamflow- Downstream Monitoring Maximum	12/14/22-12/31/22	Report	1.2968 MGD

Downstream monitoring is measured by our environmental consulting group Alliance Technical Group, formerly GBMc and Associates. Each month they pull data from their loggers, perform the necessary equations, and compile the final flows into a spreadsheet that they then send to us for reporting on the DMR. There was no measurable flow from 12/1/22 through 12/12/22. There was a rain event on 12/13/22 resulting in downstream flow on 12/13/22 and 12/14/22. The logger measured the flow until 12/14/22 at 2:30 am when their equipment malfunctioned. Therefore, we only have flow measurements for 12/13/22 and part of 12/14/22. We had several other rain events throughout the month on 12/20, 12/29, and 12/30 that have no downstream flow data due to the equipment malfunction. We have submitted the values for the available flow data from the 12/13 and 12/14, but this is not an accurate assessment of the whole month. The equipment has since been relaunched and is in operation as of 1/4/23.