

**NPDES Permit No.  
AR0000752  
El Dorado Chemical Company  
Outfalls 006 and 007  
Non-Compliance Report  
January 2023**

<b>Parameter</b>	<b>Date</b>	<b>Permit Limit</b>	<b>Reported Value</b>
Streamflow-Downstream Monitoring Monthly average	1/1/23-1/3/23	Report	1.6876 MGD
Streamflow-Downstream Monitoring Maximum	1/1/23-1/3/23	Report	14.9025 MGD

Downstream monitoring is measured by our environmental consulting group Alliance Technical Group, formerly GBMc and Associates. Each month they pull data from their loggers, perform the necessary equations, and compile the final flows into a spreadsheet that they then send to us for reporting on the DMR. A rain event occurred on 1/2/23-1/3/23 resulting in downstream flow that is not completely accounted for due to equipment malfunction. The logger malfunctioned on 12/14/22 at 2:30 am and was not reset until 1/3/23. Therefore, we only have complete flow measurements for 1/4/23 through 1/31/23. We do have partial data from 1/3/23 but not for the entire day. We have submitted the values for the available flow data from 1/3/23-1/31/23, but this does not include the data for 1/1/23 until the equipment was reset on 1/3/23.