

NPDES Permit No. AR0000752
El Dorado Chemical Company
Outfall 010 Non-Compliance Report
August 2022

All parameters sampled at 010 were within permit limits except for the following:

Parameter	Date	Permit Limit	Sample Result
NH3-N Daily Average	8/2,3,4,9,10,11,16,	265.2 lbs/day	364.71 lbs/day
NH3-N Daily Average	8/18,24,30,31, 2022	265.2 lbs/day	364.71 lbs/day
NH3-N Daily Maximum	8/30/2022	605 lbs/day	696.97 lbs/day
NH3-N Daily Maximum	8/31/2022	605 lbs/day	713.01 lbs/day

The flooding event took place in a very short time frame and the entire area was flooded and caused unprecedented amount of water to be pushed throughout the plant and caused elevated concentrations throughout.

-

-