

NPDES Permit No. AR0000752
El Dorado Chemical Company
Outfall 010 Non-Compliance Report
November 2022

All parameters sampled at 010 were within permit limits except for the following:

Parameter	Date	Permit Limit	Sample Result
Nitrogen, ammonia total [as N] Monthly Average	11/1 through 11/30 2022	265.2 lbs./day	321.78 lbs./day

Concentration limitations for Ammonia-Nitrogen (NH₃-N) exceed our permit by 21%. Due to the numerous rain events, the amount of NH₃-N in our storage lagoon has elevated. In order to manage our lagoon levels, it will take time for the elevated concentrations to decrease. El Dorado Chemical Company has hired consultants that are currently analyzing the water balance for the facility as we work to develop plans to reduce the source load at the facility.

-