

NPDES Permit No. AR0000752
El Dorado Chemical Company
Outfall 010 Non-Compliance Report
October 2022

All parameters sampled at 010 were within permit limits except for the following:

| Parameter | Date | Permit Limit | Sample Result |
|---|----------------------------|---------------------|----------------------|
| Nitrogen, ammonia total [as N] Monthly Average | 10/1 through 10/31 2022 | 265.2 lbs./day | 309.41 lbs./day |

Rainfall amounts in early July of 2022 has caused the concentrations limitations for Ammonia-Nitrogen (NH₃-N) to exceed our permit. This event has taken considerable time to work through the wastewater system.

-