

Leslie Allen-Daniel (adpce.ad)

From: Charles McDowell <CMcDowell@lsbindustries.com>
Sent: Friday, February 9, 2024 12:40 PM
To: Richard Healey (adpce.ad); Water-Enforcement-Report
Cc: Keith Long; Howard Stevens
Subject: Outfall 001: NPDES AR0000752

Currently Lake Kildeer is at 17.06 feet with a freeboard of 0.44 feet. Current weather forecast indicates an additional 2.4 inches of rain are expected to fall in the next 4 days. Based upon the current level in Lake Kildeer and the future weather forecast, it is anticipated that we will overtop the Kildeer spillway on the 11th or 12th of February unless immediate measures are taken. If the spillway overtops, it could compromise the integrity of the levee and the possibility of the levee failing. This is an upset condition outlined in Part III.B.5 of AR0000752.

At 12:12 pm on the 9th of February, the facility opened Outfall 001 to prevent Kildeer from overtopping and continues to operate Outfall 010 near the 2.0 MGD capacity to reduce the volume of water in Lake Kildeer. In accordance with Emergency Contingency Plan for Significant Rain Events.

Initial verbal notification was made at 12:06 pm on the 9th of February and a voice mail was left. EDCC will provide email notice when the upset condition has stopped. If you have any questions, feel free to contact me at 870-863-1403 or 870-310-6696.

Charles McDowell | Environmental Leader | LSB INDUSTRIES, Inc. (NYSE: LXU) | El Dorado Chemical Plant | 4500 North West Avenue, El Dorado, Arkansas 71731

 O: 870-863-1403 |  M: 870-310-6696 |  E: email cmcdowell@lsbindustries.com