

February 23, 2016

Arkansas Department of Environmental Quality Water Enforcement Branch 5301 Northshore Drive North Little Rock, AR 72118-5317

RE: NPDES Permit AR0000752 Discharge Monitoring Report for period ending January 31, 2016.

Enclosed you will find the Discharge Monitoring Reports ending January 31, 2016.

If you have any questions regarding this report, please contact Edward L Pearson at (870) 863-1400.

Sincerely,

**Edward L Pearson** 

**Environmental Technician** 

**Enclosures** 

## **NON-COMPLIANCE REPORT**

AFIN:

Facility Name:

**El Dorado Chemical Company** 

Permit Number: AR0000752

70-00040

Month / Year:

Jan-16

	[ <del>'''''                                </del>		>	y vandation to a second
Type of Violation	Permit Limit	Date of Violation	Cause of Violation	Corrective Action or Other Narrative
Outfall 006 / Lead Monthly Average (33 ug/L)	3.8 ug/L Monthly Average	1/31/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 006 / Lead Daily Max. (39 ug/L)	7.62 ug/L. Daily Max.	1/7/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 006 / Lead Daily Max. (27 ug/L)	7.62 ug/L Daily Max.	1/22/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 006/ Zinc Monthly Average (895 ug/L)	115.62 ug/L Monthly Average	1/31/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 006/ Zinc Daily Max.(1100 ug/L)	231.99 ug/L Daily Max.	1/7/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 006/ Zinc Daily Max.(690 ug/L)	231.99 ug/L Daily Max.	1/22/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 006/ TDS Monthly Average (345 mg/L)	291 mg/L Monthly Average	1/31/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 006/ TDS Daily Max.(450 mg/L)	436.5 mg/L Daily Max	1/7/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 007 / TDS Monthly Average (815 mg/L)	291 mg/L Monthly Average	1/31/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 007/ TDS Daily Max.(1300 mg/L)	436.5 mg/L Daily Max	1/7/2016	Unknown	EDCC has applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
TCERTIFY THAT UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of				Kely Jlurie 2.23-16
between 6 months and 5 years.)				Signature / Date