

4500 NORTH WEST AVE. • P. O. BOX 231 • EL DORADO, AR 71731 • (870) 863-1400



CHEMICAL COMPANY

July 23, 2014

Arkansas Department of Environmental Quality
Water Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

RE: NPDES Permit AR0000752 Discharge Monitoring Report for period ending June 30, 2014.

Enclosed you will find the Discharge Monitoring Reports ending June 30, 2014. The DMR's for Outfall 010-A were entered on the blank DMR forms provided by Amy Schluterman, ADEQ Water Enforcement.

If you have any questions regarding this report, please contact Barry Rowe at (870) 863-1400.

Sincerely,

A handwritten signature in black ink, appearing to read "Greg Withrow", with a long horizontal flourish extending to the right.

Greg Withrow
General Manager

Enclosures

NON-COMPLIANCE REPORT

Facility Name: *El Dorado Chemical Company*

Permit Number: *AR0000752*

AFIN:

70-00040

Month / Year: *Jun-14*

Type of Violation	Permit Limit	Date of Violation	Cause of Violation	Corrective Action or Other Narrative
Outfall 006 / Zinc Monthly Average (140.0 ug/L)	115.62 ug/L Monthly Average	6/11/2014	Unknown	EDCC continues to monitor and evaluate potential sources of the Zinc excursion.
Outfall 006 / Lead Monthly Average (20.30 ug/L)	3.8 ug/L Monthly Average	6/11/2014	Unknown	EDCC continues to monitor and evaluate potential sources of the Lead excursion.
Outfall 006 / Lead Daily Max (20.30 ug/L)	7.62 ug/L Daily Max.	6/11/2014	Unknown	EDCC continues to monitor and evaluate potential sources of the Lead excursion.
Outfall 010 / Zinc Monthly Average Loading (35.96 lb/day)	7.35 lb/day Monthly Average	6/11/2014	Unknown	Special Sampling has taken place and EDCC discovered galvanized piping was used to connect the 24 hour ISCO sampler. This was changed on June 18th to Stainless steel and the zinc results are now in compliance.
Outfall 010 / Zinc Daily Max Loading (35.96 lb/day)	14.75 lb/day Daily Max	6/11/2014	Unknown	Special Sampling has taken place and EDCC discovered galvanized piping was used to connect the 24 hour ISCO sampler. This was changed on June 18th to Stainless steel and the zinc results are now in compliance.
Outfall 003 / TSS Monthly Average (4.0 lb/Day)	2.1 lb/Day Monthly Average	6/17/2014	Unknown	EDCC has land applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 003 / TSS Daily Max (4.0 lb/Day)	3.3 lb/Day Daily Max	6/17/2014	Unknown	EDCC has land applied pelletized lime in the area of outfall 006 in an effort to promote vegetative cover.
Outfall 010/ pH No test results	6.0 S.U. Minimum / 9.0 S.U. Maximum	6/11 & 12/2014	Lab failure	Due to incubator failure at American Interplex the Fecal Coliform control failed to meet acceptance criteria.
<p>I CERTIFY THAT UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)</p>				<p style="text-align: center;"><i>[Signature]</i> 7/23/14</p> <p>Signature / Date</p>

FedEx[®] Express

Extremely Urgent

Shipping, Meet Sustainability.

Now, getting it there on time also means getting it there sustainably, because FedEx works with BP Target Neutral to use carbon offsets for every

For FedEx Express[®] Shipments Only

Contents should be compatible with the container and packed securely. For shipping terms and conditions and our limits of liability, refer to the applicable FedEx Service

Page 1 of 1

services,
fedex.com

Insert shipping document here.

From: (870) 863-1121
Barry Rowe
El Dorado Chemical Co.
P. O. Box 231

Origin ID: ELDA



J142014961903uv

El Dorado, AR 71730

SHIP TO: (501) 682-0744

BILL SENDER

ADEQ - Water Division Enforcement
5301 NORTHSHORE DR

NORTH LITTLE ROCK, AR 72118

Ship Date: 24JUL14
ActWgt: 0.1 LB
CAD: 5887030/NET3550

Delivery Address Bar Code



Ref #
Invoice #
PO #
Dept #

FRI - 25 JUL 10:30A
PRIORITY OVERNIGHT


TRK# 7706 7832 3351
0201

72118
AR-US
LIT

X2 LITA



52202ED4F8A03



RT 177 1 A
ST 3 3351
07.25