



July 21, 2017

Adriane Rogers, Evron. Manager
Great Lakes Chemical - Central Plant
P.O. Box 7020
El Dorado, AR 71731

Email<adriane.rogers@chemtura.com>

RE: NPDES Permit Number AR0001171, AFIN 70-00012
Effluent Violation Warning

Dear Ms. Rogers:

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violations of the effluent limitations in Part I, Section A of your Permit for the reporting periods ending April 30, 2017 and May 31, 2017:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
05/31/2017	002-A	pH, MINIMUM, SU	≥ 6	5.3	%
05/31/2017	003-A	pH, MINIMUM, SU	≥ 6	5.9	%
05/31/2017	004-A	pH, MINIMUM, SU	≥ 6	5.5	%
05/31/2017	003-A	Chloride [as Cl], MO AVG, mg/L	31	45	45%
05/31/2017	003-A	Solids, total dissolved, MO AVG, mg/L	201	209	4%
04/30/2017	002-A	pH, MINIMUM, SU	≥ 6	4.9	%
04/30/2017	003-A	pH, MINIMUM, SU	≥ 6	5.5	%
04/30/2017	004-A	pH, MINIMUM, SU	≥ 6	5.7	%
04/30/2017	003-A	Chloride [as Cl], MO AVG, mg/L	31	38.2	23%

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or e-mail pemberton@adeq.state.ar.us.

Sincerely,

Layne Pemberton, Enforcement Analyst,
Office of Water Quality, NPDES Enforcement Section