



# ARKANSAS

## ENERGY & ENVIRONMENT

February 16, 2021

Tommy D. Smith, VP of Mfg.  
Georgia-Pacific Consumer  
P.O. Box 3333  
Crossett, AR 71635

email: Sara M. Ross: [sarah.ross@gapac.com](mailto:sarah.ross@gapac.com)

RE: NPDES Permit Number AR0001210 AFIN 02-00013  
Permitted Effluent Limitation Violations

Dear Mr. Smith,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 1 violation of Part I, Section A of NPDES Permit No. AR0001210 during the review period. DEQ requires Georgia-Pacific to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at [gavin.gray@adeq.state.ar.us](mailto:gavin.gray@adeq.state.ar.us).

Sincerely,

Gavin Gray  
Enforcement Analyst  
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code
08/31/2020	SMS-A	Solids, total suspended, DAILY MX, lb/d	30000	45484	52%	E90