

From: Pemberton, Layne
To: ["Tim.Luther@CH2M.com"](mailto:Tim.Luther@CH2M.com); [Healey, Richard](#); [McDonald, Scott](#)
Cc: tnyander@fayetteville-ar.gov; Billy.Ammons@CH2M.com; Mayo.Miller@ch2m.com; Timothy.Tinsley@CH2M.com
Subject: RE: Potential Line Leak Noland WWTP, AFIN #7200781 Permit #AR0020010
Date: Tuesday, November 10, 2015 12:27:00 PM
Attachments: [image003.png](#)

Mr. Luther,

Your notification is noted. Please provide the Department with weekly updates via email until the problem is resolved.

Thank you,

Layne Pemberton
Enforcement Analyst
ADEQ Water Division
Enforcement Branch
Phone: 501-682-0664
Fax: 501-682-0880
pemberton@adeq.state.ar.us



From: Tim.Luther@CH2M.com [mailto:Tim.Luther@CH2M.com]
Sent: Friday, October 30, 2015 3:50 PM
To: [Healey, Richard](#); [Pemberton, Layne](#)
Cc: tnyander@fayetteville-ar.gov; Billy.Ammons@CH2M.com; Mayo.Miller@ch2m.com; Timothy.Tinsley@CH2M.com
Subject: Potential Line Leak Noland WWTP, AFIN #7200781 Permit #AR0020010

Mr. Healey,

We wish to inform you of a potential leak in the holding pond return line at the Noland WWTP, AFIN #7200781 Permit #AR0020010. The leak has not been confirmed but the suspected line has been isolated. This line was being used to empty a tank as part of the ongoing plant upgrade construction. This pond return line also receives flow from the Biosolids Management Site pump station. We have shut that system down as well while we investigate further. The line may need to be utilized to pump rain water depending on the rain forecast and the amount received. The City of Fayetteville Water & Sewer staff will investigate to determine if a leak exists and we will keep you informed. We have found no evidence of the suspected leak leaving the plant site.

Thank you for taking my call this afternoon and please call me on my cell phone at (479) 790-4747 if you have any questions.

Best Regards,

Tim Luther

Operations Manager

D 479 443 3292

F 479 443 5613

CH2M

1400 N Fox Hunter Road

Fayetteville, AR 72701