

ADEQ

ARKANSAS
Department of Environmental Quality

January 11, 2016

Honorable Lioneld Jordon
Mayor, City of Fayetteville
1500 N Fox Hunter Road
Fayetteville, AR 72701

RE: NPDES Permit Number AR0020010, AFIN 72-00781
Effluent Violation Warning

Dear Mayor Jordon:

A review of the above referenced facility reveals the following exceedances during 2015:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	Violation Code
10/31/2015	001-B	BOD, carbonaceous [5 day, 20 C], MO AVG, mg/L	5.5	8.6	E90
10/31/2015	001-B	BOD, carbonaceous [5 day, 20 C], 7 DA AVG, mg/L	8.3	18	E90

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or you may e-mail me at pemberton@adeq.state.ar.us.

Sincerely,



Layne Pemberton
Enforcement Analyst
NPDES Enforcement Section