

From: [Miller, Mayo/Fay](#)
To: [Pemberton, Layne](#)
Cc: [Luther, Tim/FAY](#); [Weeks, Greg/FAY](#); "Nyander, Tim"; [Hyke, Lynn](#); [Hickle, Jeff/FAY](#)
Subject: 3 May, 2018 - Fayetteville Lift-station SSO Notice
Date: Friday, May 04, 2018 4:51:59 PM

Mr. Pemberton,

We wish to inform you that between Thursday May 3, 2018 and Friday May 4, 2018, the Fayetteville region received approximately 3 inches of rainfall within 24 hours. Unfortunately, two lift station pumping capacities were exceeded resulting in sanitary sewer overflows from two manholes. Approximately 20,000 gallons of highly diluted raw wastewater was released from the manholes into receiving waters.

No adverse environmental impacts have been observed.

SSO reports for these two overflows have been submitted online and have the following confirmation numbers:
bd8c871b-3fae-48b5-93cb-57f942a4d172 (LS# 18 - Greenland)
ecc828c7-17e5-4881-973a-a955ba150d4c (LS#19 - Mally Wagnon)

If you have any additional questions or concerns, please don't hesitate to contact me.

Have a good weekend!

Mayo Miller
Jacobs
Project Manager
479-443-3292
435-690-1955 mobile
mayo.miller@jacobs.com
-
www.jacobs.com

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.