

Pemberton, Layne

From: Hickle, Jeff/FAY <Jeff.Hickle@jacobs.com>
Sent: Monday, July 6, 2020 11:46 AM
To: Pemberton, Layne
Cc: Luther, Tim/FAY; Weeks, Greg/FAY; Nyander, Tim; Hyke, Lynn; Benton, Matthew/FAY; Genz, Jerry/FAY; Granderson, Corey; Vinson, Thom/FAY; Alleman, Joshua
Subject: Unpermitted Discharge Notification - 04 July, 2020 - Paul R Noland WWTF - AR0020010, AFIN 72-00781

Good afternoon Mr Pemberton,

I wanted to send notification that Saturday afternoon, July 04th, the Noland facility experienced an unpermitted release of fully treated W3 effluent from an unexpected line break, estimated to be 200,000 gallons, some of which drained into a nearby unnamed tributary of Roberts Creek, a tributary of the White River. The initial response was to stop the W3 release by shutting off the Effluent Pump Station's W3 pump. Facility and city's Utility staff are currently working on a permanent line repair. Repairs are anticipated to be completed by end of the day.

No adverse environmental impacts have been observed.

Thank you and an online report has already been submitted.

CONFIRMATION NUMBER

3729a075-abe1-47ed-a964-d1bdc6d56f13

Jeff Hickle
Environmental Scientist
D 479 443 3292
M 479 445 5676

CH2M is now Jacobs.
1400 N Fox Hunter Road
Fayetteville, AR 72701
www.jacobs.com | [LinkedIn](#) | [Twitter](#) | [Facebook](#) | [Instagram](#)

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.