From: <u>Tim.Luther@CH2M.com</u>
To: <u>Pemberton, Layne</u>

Cc: tnyander@fayetteville-ar.gov; hybe@fayetteville-ar.gov; <a href="mailto:hy

Michelle.Strange@CH2M.com; Thom.Vinson@ch2m.com; Jeff.Hickle@ch2m.com

Subject: RE: 5-Day Report - Fayetteville, Arkansas Noland WRRF, NPDES Permit AR0020010 AFIN-72-00102 Effluent Spill

Date: Friday, February 03, 2017 3:06:56 PM

Mr. Pemberton,

The following is a written follow up to our verbal discussion regarding the effluent spill at the Fayetteville, Arkansas Noland WRRF, NPDES Permit AR0020010 AFIN-72-00102:

The City of Fayetteville crews have not been able to stop the leak on the 60" effluent discharge line at the Noland WRRF. For the past 48 hours we have been diverting the plant influent flow to the influent holding pond and not sending any influent to bioprocess. At this point all effluent that has been spilled has been treated and should meet our permit requirements (the wait on the 5 day BOD test results is the reason we cannot positively say the spilled effluent is not in 100% compliance).

We are to the point that we will need to start sending influent flow to our bioprocess to feed the micro-organisms. We expect spikes in our effluent permitted parameters when discharge resumes. Once process flows are resumed we will be sending the plant effluent to the effluent holding pond until the effluent meets permitted limits. The 60" effluent pipe that has the leak is also the pipe that sends flow to the effluent holding pond. If the pipe still leaks we will take precautionary measures to collect and pump any potential spilled material to the effluent holding pond for later treatment. We will be collecting plant effluent samples to determine if any potential spilled effluent met permitted requirements.

Please do not hesitate to call if you have any question. Have a great weekend!

Best Regards,

Tim Luther

Operations ManagerD 479 443 3292C 479 790 4747F 479 443 5613

CH2M

1400 N Fox Hunter Road Fayetteville, AR 72701

From: Pemberton, Layne [mailto:PEMBERTON@adeq.state.ar.us]

Sent: Wednesday, February 01, 2017 9:14 AM **To:** Hickle, Jeff/FAY <Jeff.Hickle@ch2m.com>

Cc: tnyander@fayetteville-ar.gov; lhyke@fayetteville-ar.gov; Carpenter, Steven/CRP <Steven.Carpenter@ch2m.com>; Miller, Mayo/Fay <Mayo.Miller@ch2m.com>; Luther, Tim/FAY <Tim.Luther@CH2M.com>; Strange, Michelle/FAY <Michelle.Strange@CH2M.com>; Vinson, Thom/FAY <Thom.Vinson@ch2m.com>

Subject: RE: 5-Day Report - Fayetteville, Arkansas Noland WRRF, NPDES Permit AR0020010 AFIN-72-00102 Effluent Spill [EXTERNAL]

Mr. Hickle,

Your report has been received and will be reviewed.

Thank you,

Layne Pemberton
Enforcement Analyst
ADEQ Office of Water Quality
Enforcement Branch

Phone: 501-682-0664 Fax: 501-682-0880

pemberton@adeq.state.ar.us



From: Jeff.Hickle@ch2m.com [mailto:Jeff.Hickle@ch2m.com]

Sent: Tuesday, January 31, 2017 2:06 PM

To: Pemberton, Layne

Cc: tnyander@fayetteville-ar.gov; lhyke@fayetteville-ar.gov; Steven.Carpenter@ch2m.com;

Mayo.Miller@ch2m.com; Tim.Luther@CH2M.com; Michelle.Strange@CH2M.com;

<u>Jeff.Hickle@ch2m.com</u>; <u>Thom.Vinson@ch2m.com</u>

Subject: 5-Day Report - Fayetteville, Arkansas Noland WRRF, NPDES Permit AR0020010 AFIN-

72-00102 Effluent Spill

Mr. Pemberton,

Below is the requested 5-day written report for spill of effluent at the Noland WRRF, Fayetteville AR – AFIN #72-00102, NPDES Permit #AR20010.

Permittee Name: City of Fayetteville-Paul R. Noland Wastewater Treatment Plant

Permit Number: AR0020010

Location of Spill: 1400 N Fox Hunter Rd.

Date on which the Spill occurred: 01/30/17 – Present

Amount of water that was bypassed: Approximately 1 MGD

While completing PM's at the Noland WRRF (Permit #AR0020010 AFIN # 72-00781) on Monday January 30th at 11:00 am, a mechanic noticed a leak of water from the ground near the Effluent Pump Station.

Although it has not yet been confirmed, the leak appears to be coming from the plant's 60 inch effluent discharge line. The approximate 700 gpm, or 1 MGD, flow originates from under a rip-rap bouldered embankment and into the nearby White River.

The quality of water in the effluent line is fully expected to meet all permit requirements; as a result, no adverse environmental impact has been observed and none is expected.

Also please note the spill of effluent occurs post all treatment processes but also prior to the facility's Effluent Parshall Flume; the portion of effluent lost prior to the Parshall Flume will be unmeasured thus effecting DMR monthly average pounds per day (lbs/day) permit limits calculations.

Efforts are currently being made to use more sophisticated leak detection technology and heavy excavation equipment has been mobilized to expose the 20 foot deep, 60 inch effluent line.

We will keep you apprised of the situation as we gather more information. If you have any questions, please let us know.

Sincerely Jeff Hickle

Environmental Projects Specialist (479) 445-5676 jeff.hickle@ch2m.com