

From: [Luther, Tim/FAY](#)
To: [Pemberton, Layne](#)
Cc: [Weeks, Greg/FAY](#); [Miller, Mayo/Fay](#); [Vinson, Thom/FAY](#); [Hickle, Jeff/FAY](#)
Subject: 3 January, 2018 - Fayetteville Paul R Noland WWTP (AFIN #72-00781, AR0020010) Unpermitted Discharge
Date: Thursday, January 04, 2018 1:36:25 PM
Attachments: [SSO Report_4459f1ae-e55a-4919-b550-b39ea4f2f6d6.html](#)

Fayetteville, Arkansas Noland NPDES Permit Number AR0020010, AFIN 72-00781
Unpermitted Discharge

Mr. Pemberton,

On 3 January 2018, Fayetteville had been experiencing several previous days of below freezing temperatures with some wind chill temperatures below zero. Because of these freezing temperatures a two-inch insulated and heat traced plant reuse water line froze and broke. This reuse water is the plants treated effluent and at the time of the break the plants effluent met all permit discharge requirements. The break occurred at 4:12 p.m. and the leak was isolated at 4:19 p.m. with an estimated 700 gallons spilled. The treated effluent from this unpermitted discharge was contained within the grassy area at the Noland Water Resource Recovery Facility. I have attached a copy of the 24 hour on-line Unpermitted Discharge Reporting Form.

No adverse environmental impacts occurred.

Please let me know if you have any questions or concerns.

Best regards,

Tim Luther

Operations Manager

D 479 443 3292

C 479 790 4747

F 479 443 5613

CH2M is now Jacobs!

1400 N Fox Hunter Road
Fayetteville, AR 72701