

From: Pemberton, Layne
To: "Tim.Luther@CH2M.com"
Cc: tnyander@fayetteville-ar.gov; lhyke@fayetteville-ar.gov; Steven.Carpenter@ch2m.com; Mayo.Miller@ch2m.com; Michelle.Strange@CH2M.com; Timothy.Tinsley@CH2M.com; Thom.Vinson@ch2m.com; McDonald.Scott
Subject: RE: Fayetteville, Arkansas Noland WRRF, NPDES Permit AR0020010 AFIN-72-00781 Effluent Discharge with No Disinfection
Date: Tuesday, September 06, 2016 9:59:00 AM

Tim,

Your report has been received and will be reviewed. Please keep the Department abreast of any changes or environmental effects.

Thank you,

Layne Pemberton
Enforcement Analyst
ADEQ Office of Water Quality
Enforcement Branch
Phone: 501-682-0664
Fax: 501-682-0880
pemberton@adeq.state.ar.us



From: Tim.Luther@CH2M.com [mailto:Tim.Luther@CH2M.com]
Sent: Monday, September 05, 2016 8:30 PM
To: Pemberton, Layne
Cc: tnyander@fayetteville-ar.gov; lhyke@fayetteville-ar.gov; Steven.Carpenter@ch2m.com; Mayo.Miller@ch2m.com; Michelle.Strange@CH2M.com; Timothy.Tinsley@CH2M.com; Thom.Vinson@ch2m.com
Subject: Fayetteville, Arkansas Noland WRRF, NPDES Permit AR0020010 AFIN-72-00781 Effluent Discharge with No Disinfection

Mr. Pemberton,

On Monday September 5th at 06:46 the on-duty Operator noticed that the Noland WRRF, Permit #AR0020010 AFIN # 72-00781, effluent disinfection system was off line. The Operator immediately responded to stop discharge to White River and flow to White River was stopped at 07:05. Further investigation revealed that the disinfection system failed on September 4th at 21:22. During the approximate nine hours and forty three the disinfection system was off line 1.67 million gallons was discharged into the White River. On call staff responded and added an additional disinfection alarm to the supervisory control and data acquisition (Scada) system to prevent this type of incident in the future. No environmental impact has been

observed.

Best regards,

Tim Luther

Operations Manager

D 479 443 3292

F 479 443 5613

CH2M

1400 N Fox Hunter Road

Fayetteville, AR 72701