

From: Hickle, Jeff/FAY [<mailto:Jeff.Hickle@jacobs.com>]

Sent: Wednesday, December 2, 2020 12:51 PM

To: Healey, Richard

Cc: Weeks, Greg/FAY; Nyander, Tim; Hyke, Lynn; Benton, Matthew/FAY; Granderson, Corey; Alleman, Joshua; Ramsfield, Austin/FAY; Blythe, Bob; Judy, Bryan; Sedlak, MONTY/NOR; Vinson, Thom/FAY

Subject: Unpermitted Discharge Notification - 01 December, 2020 - Paul R Noland WWTF [AR0020010, AFIN 72-00781]

Good afternoon Mr Healey,

I wanted to send notification that Tuesday afternoon, December 01st, the Noland WWTF experienced an unpermitted release of fully treated W3 effluent from an unexpected PVC line failure, estimated to be 40,000 gallons.

The W3 release was stopped within 5 minutes of discovery by closing a nearby isolation valve.

The effluent was partially released into a containment trough that directs the W3 effluent back to the facility's headworks; the remaining portion of released W3 flowed onto a nearby grassy area where some runoff did reach an unnamed intermittent stream connected to the White River.

The broken 2" W3 line remains isolated while staff schedule replacement of the aged piping and fittings; also staff will explore options for protecting the replaced pipe from UV exposure to insure against a similar failure in the future.

Additionally the W3 line will be taken offline as a winterization precaution as it is only used during the summer months.

No adverse environmental impacts have been observed and none are expected.

Thank you, an online report has already been submitted, and please feel free to reach out to me if you have any questions.

CONFIRMATION NUMBER

3aedb0b5-132f-4d11-9e42-6634046c4c20

Jeff Hickle, E.I. | [Jacobs](#) | Environmental Specialist
O:479.443.3292 | M:479.445.5676 | jeff.hickle@jacobs.com
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA
www.jacobs.com

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.