

Kristen Graham (adpce.ad)

From: Hickle, Jeff <Jeff.Hickle@jacobs.com>
Sent: Friday, May 26, 2023 5:28 PM
To: Kristen Graham (adpce.ad)
Cc: SSOADEQ; Guy, Jan; Weeks, Greg; Vinson, Thom; Nyander, Tim; Santellanes, Shawn; Thomas Harrington (adpce.ad); Miller, Mayo; Alleman, Joshua
Subject: 5-Day Incident Update - RE: Unpermitted Discharge Notification (May 25) - Paul R Noland WWTF [AFIN 72-00781, AR0020010]

Good afternoon Ms Graham,

I'm sending an update to yesterday's unpermitted discharge incident that the W3-effluent line break was located and repaired earlier this morning.

Following yesterday's notification submittal, only an additional 50 gallons of W3-effluent is estimated as released onto facility grounds only during the process of finding and repairing the damaged pipe area.

Again, no adverse environmental impacts have been observed and none are expected.

Thank you and please let me know if additional incident reporting steps are needed.

Best Regards,

Jeff Hickle, E.I. | [Jacobs](#) | Environmental Specialist
O:479.443.3292 | M:479.445.5676 | jeff.hickle@jacobs.com
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA
www.jacobs.com

From: Hickle, Jeff
Sent: Thursday, May 25, 2023 3:59 PM
To: Kristen Graham <kristen.graham@adeq.state.ar.us>
Cc: ssoadeq@adeq.state.ar.us; Guy, Jan <Jan.Guy@jacobs.com>; Weeks, Greg <Greg.Weeks@jacobs.com>; Vinson, Thom <Thom.Vinson@jacobs.com>; tnyander@fayetteville-ar.gov; Granderson, Corey <cgranderson@fayetteville-ar.gov>; Santellanes, Shawn <Shawn.Santellanes@jacobs.com>; Harrington, Thomas <Thomas.Harrington@adeq.state.ar.us>; Miller, Mayo <Mayo.Miller@jacobs.com>; jwatkins@fayetteville-ar.gov; Alleman, Joshua <Joshua.Alleman@jacobs.com>; Lancaster, Carrie <clancaster@fayetteville-ar.gov>
Subject: Unpermitted Discharge Notification (May 25) - Paul R Noland WWTF [AFIN 72-00781, AR0020010]

Good afternoon Ms Graham,

I wanted to send notification that an unpermitted release of W3-effluent was discovered this morning (Thursday, May 25) at the Paul R Noland WWTF (AFIN 72-00781, AR0020010).

The discharge of fully treated W3-effluent occurred from a buried line break just east of the facility's Influent Pump Station No.1.

The initial discharge has been stopped (approx. 08:00am) by shutting off the facility's W3 pumps shortly after discovery.

Excavation of the area is underway to find the line break and repair as appropriate.

An estimated 2,000 gallons of fully treated W3-effluent is estimated as released onto facility grounds only, no receiving waters were reached.

No adverse environmental impacts have been observed and none are expected.

Thank you and an online report has already been submitted; I will follow-up with an incident update when repairs have been completed.

CONFIRMATION NUMBER

8b992337-6e9e-4fe2-abf5-159d488d827c

Best Regards,

Jeff Hickle, E.I. | [Jacobs](#) | Environmental Specialist
O:479.443.3292 | M:479.445.5676 | jeff.hickle@jacobs.com
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA
www.jacobs.com

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.