

Kristen Graham (adpce.ad)

From: Hickle, Jeff <Jeff.Hickle@jacobs.com>
Sent: Thursday, July 13, 2023 11:19 AM
To: Kristen Graham (adpce.ad)
Cc: SSOADEQ; Guy, Jan; Weeks, Greg; Vinson, Thom; Nyander, Tim; Granderson, Corey; Santellanes, Shawn; Patton, Travis; Thomas Harrington (adpce.ad); Miller, Mayo; jwatkins@fayetteville-ar.gov; Lancaster, Carrie
Subject: Spill-Upset Reporting Notification (July 12) - Paul R Noland WWTF [AFIN 72-00781, AR0020010]
Attachments: Confirmation_Report.pdf

Good afternoon Ms Graham,

I wanted to send notification that an spill-upset occurred yesterday morning (Thursday, July 12) at the Paul R Noland WWTF (AFIN 72-00781, AR0020010).

During routine (backflushing) of a clarifier scum pump, Operators noticed a small amount of water coming through the sidewalk cracks just outside the scum-pump building for Clarifiers No.3 & No.4.

The spill was untreated wastewater, estimated 200-gallons, onto facility grounds resulting from a line failure of the scum-pit's buried drain-pipe.

Operators stopped the spill-upset by taking Clarifier No.3 offline. The clarifier will remain offline, and drain line isolated, until line repairs have been completed.

Again, a total estimated 200 gallons of untreated wastewater was released onto facility grounds only, no receiving waters were reached.

No adverse environmental impacts have been observed and none are expected.

Thank you and the attached online report has already been submitted.

CONFIRMATION NUMBER

fb8f7ee8-c3aa-4612-a041-a00611e4c44e

Best Regards,

Jeff Hickle, E.I. | [Jacobs](#) | Environmental Specialist
O:479.443.3292 | M:479.445.5676 | jeff.hickle@jacobs.com
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA
www.jacobs.com

viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.