

## Kristen Graham (adpce.ad)

---

**From:** Hickle, Jeff <Jeff.Hickle@jacobs.com>  
**Sent:** Wednesday, January 17, 2024 10:29 AM  
**To:** Kristen Graham (adpce.ad)  
**Cc:** SSOADEQ; Weeks, Greg; Miller, Mayo; Vinson, Thom; Nyander, Tim; Granderson, Corey; Santellanes, Shawn; Thomas Harrington (adpce.ad); jwatkins@fayetteville-ar.gov; Lancaster, Carrie; Harrold, Ryan  
**Subject:** Spill-Upset Reporting Notification (January 16) - Paul R Noland WWTF [AFIN 72-00781, AR0020010]  
**Attachments:** ADEQ\_Confirmation-Report.pdf

Good morning Ms Graham,

I'm sharing a second notification that a spill-upset also occurred Tuesday morning (January 16) at the Paul R Noland WWTF (AFIN 72-00781, AR0020010).

- Tuesday morning an Operator found an underground leak between the facility's Main Office Building and Influent Pump Station.
- We believe the leak originates from a buried drain line connected to the clarifier scum pits.
- The subsequent spill of untreated wastewater likely resulted from a break in the buried drain line, which we believe was caused by several days of sub-freezing temperatures with extraordinarily low nighttime temperatures below 0°F.
- An estimated 600 gallons of untreated wastewater could have been released from the buried line break onto facility grounds only; no receiving waters were impacted by this incident.
- Lime has been applied to the impacted area, and excavation of the area scheduled once soil thawing allows; additionally, clarifier scum pumps have been temporarily isolated to prevent any further spills.
- We'll be sure to share updates with a 5-day report following determination of drain line condition and subsequent repairs.

No adverse environmental impacts have been observed and none are expected.

Thank you and the attached online report has already been submitted.

## CONFIRMATION NUMBER

37fd6273-b739-46ba-82d7-9f375786870f

Best Regards,

**Jeff Hickle, E.I.** | [Jacobs](#) | Environmental Specialist  
O:479.443.3292 | M:479.445.5676 | [jeff.hickle@jacobs.com](mailto:jeff.hickle@jacobs.com)  
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA  
[www.jacobs.com](http://www.jacobs.com)

---

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.