

Kristen Graham (adpce.ad)

From: Hickle, Jeff <Jeff.Hickle@jacobs.com>
Sent: Friday, March 3, 2023 5:46 PM
To: Kristen Graham (adpce.ad)
Cc: SSOADEQ; Guy, Jan; Weeks, Greg; Vinson, Thom; Nyander, Tim; Granderson, Corey; Santellanes, Shawn; Thomas Harrington (adpce.ad); Miller, Mayo; jwatkins@fayetteville-ar.gov
Subject: Unpermitted Discharge Notification (Mar 03) - Paul R Noland WWTF [AFIN 72-00781, AR0020010]

Good afternoon Ms Graham,

I wanted to send notification that an unpermitted release of (belt-filter press) process water occurred at the Paul R Noland WWTF (AFIN 72-00781, AR0020010).

Back-up overflows occurred at two Influent Pump Station (IPS) connected yard drains today (Friday, March 03rd) during a storm-related period of elevated collection system inflow following over 3 inches of rainfall within a 15-hr period.

The unpermitted release of process water stopped at 3:08 PM once elevated inflows decreased and the facility's IPS returned to pump capacities.

An estimated 50 gallons, not recovered, reached facility grounds immediately adjacent to the process-return yard drains.

Receiving waters were not reached; no adverse environmental impacts have been observed, and none are expected.

Thank you and an online report has already been submitted.

CONFIRMATION NUMBER

ee713a09-9cc5-4808-a3dd-0b92849d798d

Best Regards,

Jeff Hickle, E.I. | [Jacobs](https://www.jacobs.com) | Environmental Specialist
O:479.443.3292 | M:479.445.5676 | jeff.hickle@jacobs.com
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA
www.jacobs.com

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.