

## Harbin, Danielle

---

**From:** Hickle, Jeff/FAY <Jeff.Hickle@jacobs.com>  
**Sent:** Monday, November 15, 2021 2:44 PM  
**To:** Harbin, Danielle  
**Cc:** Ramsfield, Austin/FAY; Vinson, Thom/FAY  
**Subject:** Numeric Correction - RE: Unpermitted Discharge Notification - Paul R Noland WWTF, AR0020010, AFIN #72-00102

Hello again Ms Harbin,  
My colleagues were kind enough to point out a small digit error in my email earlier today. I meant to express that 1,100,000 gallons on effluent left the effluent pump station. Sorry about any confusion on that point, and I've verified that the correct spill amount was reported through the online portal.

Best Regards

**Jeff Hickle, E.I.** | [Jacobs](#) | Environmental Specialist  
O:479.443.3292 | M:479.445.5676 | [jeff.hickle@jacobs.com](mailto:jeff.hickle@jacobs.com)  
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA  
[www.jacobs.com](http://www.jacobs.com)

---

**From:** Hickle, Jeff/FAY  
**Sent:** Monday, November 15, 2021 9:40 AM  
**To:** [Danielle.Harbin@adeq.state.ar.us](mailto:Danielle.Harbin@adeq.state.ar.us)  
**Cc:** Ramsfield, Austin/FAY <[Austin.Ramsfield@jacobs.com](mailto:Austin.Ramsfield@jacobs.com)>; Sedlak, MONTY/NOR <[Monty.Sedlak@jacobs.com](mailto:Monty.Sedlak@jacobs.com)>; Moreno Miranda, Leonides <[Leonides.MorenoMiranda@jacobs.com](mailto:Leonides.MorenoMiranda@jacobs.com)>; Weeks, Greg/FAY <[Greg.Weeks@jacobs.com](mailto:Greg.Weeks@jacobs.com)>; [tnyander@fayetteville-ar.gov](mailto:tnyander@fayetteville-ar.gov); Granderson, Corey <[cgranderson@fayetteville-ar.gov](mailto:cgranderson@fayetteville-ar.gov)>; Hyke, Lynn <[lhyke@fayetteville-ar.gov](mailto:lhyke@fayetteville-ar.gov)>; Vinson, Thom/FAY <[Thom.Vinson@jacobs.com](mailto:Thom.Vinson@jacobs.com)>; [rblythe@fayetteville-ar.gov](mailto:rblythe@fayetteville-ar.gov); Judy, Bryan <[bjudy@fayetteville-ar.gov](mailto:bjudy@fayetteville-ar.gov)>; Santellanes, Shawn/FAY <[Shawn.Santellanes@jacobs.com](mailto:Shawn.Santellanes@jacobs.com)>  
**Subject:** Unpermitted Discharge Notification - Paul R Noland WWTF, AR0020010, AFIN #72-00102

Good Morning Ms Harbin,  
I wanted to follow-up our 24-hr report submission with an email letting you know that on Sunday (Nov 07<sup>th</sup>) morning the Noland WWTF experienced an unpermitted discharge of approximately 1,100,00 gallons of fully treated effluent that left the effluent pump lift-station, flowed onto facility grounds and into nearby White River. The incident originated following a gate-controller error that occurred while the facility operator was resuming normal discharge to the White River. The final discharge gate, following the Parshall flume, was intended to be opened, but due to the gate-controller being set to 'AUTO' was inadvertently closed. The Operator re-opened the discharge gate shortly after discovering the situation, while Standard Operating Procedures and SCADA programming have been revised appropriately to prevent the incident from reoccurring. No adverse environmental impacts have been observed and none are expected.

The online report was submitted Sunday morning (Nov 7<sup>th</sup>), but still my apologies for this email reaching you several days after the incident.

Thank you and please feel free to reach out to me if you have any questions or additional concerns.

# CONFIRMATION NUMBER

**2eef2edd-a44b-4bca-9d7e-a11071238d95**

**Jeff Hickle, E.I.** | [Jacobs](#) | Environmental Specialist  
O:479.443.3292 | M:479.445.5676 | [jeff.hickle@jacobs.com](mailto:jeff.hickle@jacobs.com)  
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA  
[www.jacobs.com](http://www.jacobs.com)

---

NOTICE - This communication may contain confidential and privileged information that is for the sole use of the intended recipient. Any viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.