

## Kristen Graham (adpce.ad)

---

**From:** Hickle, Jeff <Jeff.Hickle@jacobs.com>  
**Sent:** Wednesday, March 22, 2023 12:06 PM  
**To:** Kristen Graham (adpce.ad)  
**Cc:** SSOADEQ; Guy, Jan; Weeks, Greg; Vinson, Thom; Nyander, Tim; Granderson, Corey; Santellanes, Shawn; Thomas Harrington (adpce.ad); Miller, Mayo; jwatkins@fayetteville-ar.gov  
**Subject:** Unpermitted Discharge Notification (Mar 20) - Paul R Noland WWTF [AFIN 72-00781, AR0020010]

Good afternoon Ms Graham,

I wanted to send notification that an unpermitted release of W3-effluent occurred at the Paul R Noland WWTF (AFIN 72-00781, AR0020010) late Monday night.

2-in hoses, connected to nearby W3-hydrants have been used this week to partially fill up the facility's East aeration basin in preparation for load testing recently installed mixers.

The night operator discovered one of the hoses had come loose from where it was secured to the basin rim, thus discharging W3-effluent onto a nearby graveled area.

The discharge was quickly stopped by closing the hydrant valve and the hose re-secured to the basin's rim to prevent another accidental release.

An estimated 8,000 gallons is estimated to have discharged onto facility grounds near the East aeration basin.

Receiving waters were not reached; no adverse environmental impacts have been observed, and none are expected.

Thank you and an online report has already been submitted.

## CONFIRMATION NUMBER

813d352c-882a-4b9c-ad82-61b445a721b6

Best Regards,

**Jeff Hickle, E.I.** | [Jacobs](#) | Environmental Specialist  
O:479.443.3292 | M:479.445.5676 | [jeff.hickle@jacobs.com](mailto:jeff.hickle@jacobs.com)  
1400 N Fox Hunter Rd | Fayetteville, AR 72701 | USA  
[www.jacobs.com](http://www.jacobs.com)

viewing, copying or distribution of, or reliance on this message by unintended recipients is strictly prohibited. If you have received this message in error, please notify us immediately by replying to the message and deleting it from your computer.