



ARKANSAS ENERGY & ENVIRONMENT

February 1, 2021

Lioneld Jorday, Mayor
City of Fayetteville
113 West Mountain Street
Fayetteville, AR 71601

email: tnyander@fayetteville-ar.gov

RE: NPDES Permit Number AR0020010, AFIN 35-00016
Permitted Effluent Limitation Violations

Dear Mayor Jordan,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 3 violations of Part I, Section A of NPDES Permit No. AR0020010 during the review period. DEQ requires the City of Fayetteville to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,

Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
02/29/2020	001-B2	Coliform, fecal general, 30DA GEO, #/100mL	1000	>165	99,999%	E90	74055-1-1
02/29/2020	001-B2	Coliform, fecal general, 7 DA GEO, #/100mL	2000	>1444	99,999%	E90	74055-1-1
11/30/2019	001-B2	BOD, carbonaceous [5 day, 20 C], 7 DA AVG, mg/L	8.3	8.9	7%	E90	80082-1-2