



January 25, 2016

Arkansas Department of Environmental Quality
Attn: Layne Pemberton
5301 Northshore Drive
North Little Rock, AR. 72118-5317

Re: NPDES permit AR0020010
Sanitary Sewer Overflows (SSOs)
2015 Corrective Action Plan status update

Dear Mr. Pemberton,

This is a status report on our Corrective Action Plan for sanitary sewer overflows for the calendar year of 2015.

If you need any additional information or have any questions, please call me at 479-575-8392.

Sincerely,



Mark Rogers
Operations Manager
Water & Sewer Division




Tim Nyander
Utilities Director
City of Fayetteville

FAYETTEVILLE CORRECTIVE ACTION PLAN (CAP) 2015 AR0020010

Location	Manhole #	Start Date of SSO	End Date of SSO	Est. Volume	Cause of SSO	Action(s) Taken to Address SSO	Resolution Date
1617 E. 5th, Fayetteville	W-(25)025p	01/31/15	01/31/15	100	Roots	Washed Sewer Main, Televised Sewer Main, Rootcut Sewer Main, Routine Scheduled Wash	2/25/2015
2001 W. 18th St., Fayetteville	W-(14)052 W-(14)053	01/27/15	01/27/15	25	Grease and Roots	Washed Sewer Main, Televised Sewer Main, Rootcut Sewer Main, Routine Scheduled Wash	1/29/2015
715 N. Rockcliff Rd., Fayetteville	W-(09)068 W-(09)070	01/21/15	01/21/15	50	Paper Towels, Grease and Roots	Washed Sewer Main, Televised Sewer Main, Scheduled Routine Wash, CIPP 2016	12/31/2016
2523 E. Huntsville Rd., Fayetteville	W-(09)010A	04/29/15	04/29/15	106,000	Grease & Roots	Environmental Cleanup, Washed Sewer Main, Root Cut, Televised, Repaired Sewer Main, CIPP 2016	12/31/2016
534 W. 15th St., Fayetteville	W-(18B/C)200P- W-(18B/C)199P	04/11/15	04/11/15	50	Grease	Environmental Cleanup, Washed Sewer Main, Televised, Repaired Sewer Main, Routine Scheduled Wash	5/14/2015
1782 Sioux Ct., Fayetteville	W-(43)089 W-(43)090	04/12/15	04/12/15	100	Grease and Roots	Environmental Cleanup, Washed Sewer Main, Televised, Rootcut Sewer Main, Routine Scheduled Wash	4/13/2015
116 N. Fletcher Ave., Fayetteville	W-(02)106 W-(02)108	04/08/15	04/08/15	20	Grease and Roots	Environmental Cleanup, Washed Sewer Main, Televised, Repaired Sewer Main	4/17/2015
1335 S Washington Ave., Fayetteville	W-(15)142P	05/11/15	05/11/15	10	Debris	Environmental Cleanup, Repaired Service	5/27/2015
LS# 18 210 N Sandy., Greenland	W-(32)123	05/26/15	05/26/15	250	Rain	Environmental Cleanup, Repair done	5/26/2015
518 E Lafayette St., Fayetteville	W-(02)135	05/19/15	05/19/15	10	Roots	Environmental Cleanup, Sewer Main Wash, WO, Repaired Service	6/2/2015
1434 S. West Ave. Fayetteville	W-(18B/C) 194P	05/21/15	05/21/15	10	Debris	Environmental Cleanup, Sewer Main Wash, WO, Repaired Service	5/21/2015
LS# 18 210 N Sandy., Greenland	W-(32)001	05/11/15	05/11/15	2,000	R	Environmental Cleanup, Repair done	5/12/2015
1101 S. Beechwood Ave., Fayetteville	W-(14)112-113	06/01/15	06/01/15	33,000	Debris, Obstruction in Main	Environmental Cleanup, Washed Sewer Main, Televised Sewer Main, Routine Scheduled Wash	6/1/2015
650 W Center St., Fayetteville	W-(18BC)136	06/22/15	06/22/15	10	Debris, Damage by Contractor	Washed Sewer Main, Televised Sewer Main, Contractor Relocate Main	6/22/2015
1647 W Maple St., Fayetteville	W-(13a)181	08/03/15	08/03/15	25	Roots	Washed Sewer Main, Repaired Sewer Main	8/12/2015
401 24th St. Bld D #70., Fayetteville	W-(05)051	08/14/15	08/14/15	12,000	Grease and Debris	Environmental Cleanup, Washed Sewer Main, Manholes Repaired	8/31/2015
1540 W. Markham Rd., Fayetteville	W-(13A)207 W-(13A)165	09/21/15	09/21/15	10	Roots	Environmental Cleanup, Washed Sewer Main, WO, Repair Made	11/13/2015
620 N. Rockcliff Rd., Fayetteville	W-(09)048E- W(09)048F	11/03/15	11/03/15	25	Roots	Environmental Cleanup, Washed Sewer Main, CIPP completed 01/14/2016	1/14/2016
2375 S. School Ave., Fayetteville	W-(05)011 W-(05)012	12/02/15	12/02/15	50	Line Failure	Washed and Rodded Sewer Main, Root Cut	12/2/2015

City of Fayetteville
113 W Main St.
Fayetteville, AR 72701



ADEQ, Attention Layne Pemberton
5301 Northshore Dr.
North Little Rock, AR 72118