

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0020036

Discharge Number: 001-A

Facility: CITY OF MELBOURNE WWTP

Address: AR HWY 9 SPUR (CIRCLE DRIVE)

City: MELBOURNE

State: AR

Zip: 72556

Contact: *Coy Dole*

Phone: *870-291-7773*

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1/4/23	TRC INSTANTANEOUS MAX		0.27	0.011
1/30/23	TRC INSTANTANEOUS MAX		0.14	0.011

We feel this problem was due to:

*The state of the wastewater plant it's falling apart catwalks are rusted. The Clarifier is rotting.*

We plan on correcting the problem in this manner:

*We are supposed to have a project to revamp the wastewater plant to make maintenance easier. We are supposed to have a grant in the works. And we plan on ~~doing~~ trying to ~~improve~~ improve with our do. testing.*

Time estimated that it will take to correct problem:

*Whenever we get the grant for the restoration of the plant.*

Sincerely,

*Coy Dole*

*2-21-23*

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)