

REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR020036 001-A

PERIOD ENDING July 2018

PARAMETER VIOLATED	FECAL 30DA GEO	FECAL 7 DAY GEO						
REPORTED VIOLATIONS	421	627						
PARAMETER VIOLATED	200	400						

WEEK OF 7/6/18


Please fill out the following information

CAUSE OF VIOLATION We were in violation on such date because at waste water plant, we had a ~~star~~ Rotor break down and chlorine levels needed to be adjusted as well

DURATION OF VIOLATION 2 weeks

CORRECTIVE ACTION partially corrected by repairing our rotor and correcting our chlorine levels, and a more permanent correction by redesigning and updating our waste treatment plant starting in december 2018

EXPECTED COMPLIANCE DATE rotor repaired as of 9-14-18, redesign/update date: UA




 SIGNATURE / DATE

City of Melbourne

63 Municipal Dr.
P.O. Box 800
Melbourne, AR 72556

LITTLE ROCK AR 722

18 SEP 2018 PM 3 L



ADEQ
5301 Northshore Dr.
N. Little Rock, AR 72118

72118-501799

