

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0020036 Discharge Number: _____
Facility: City of Melbourne
Address: PO Box 800
City: Melbourne State: AR Zip: 72556
Contact: Coy Dale Phone: 870-368-4215

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>June 2018</u>	<u>YOS</u>			<u>200</u>

We feel this problem was due to:
Lack of Chlorine

We plan on correcting the problem in this manner:
We added more Chlorine, and are in the planning stages of updating the wastewater plant.

Time estimated that it will take to correct problem:

Sincerely,
Coy Dale 9/17/18

Authorized Signature Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

City of Melbourne

63 Municipal Dr.
P.O. Box 800
Melbourne, AR 72556

LITTLE ROCK AR 722

18 JUL 2018 PM 4 1



ADEQ
NPDES Enforcement Section
5301 Northshore Dr.
North Little Rock, AR 72118

72118-531799

