

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality - Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0020036 Discharge Number: 001-A
 Facility: CITY OF MELBOURNE
 Address: HWY 9 SPUR; W OF CITY
 City: MELBOURNE State: AR Zip: 72556
 Contact: _____ Phone: _____

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
JUNE	FECAL 30 DAY GEO		255.0	200.0
06/02/21	FECAL 7 DAY GEO		858.0	400.0

We feel this problem was due to:

due to the age and state of the equipment at our plant, we are experiencing continued issues with regulating the wastewater plant

We plan on correcting the problem in this manner:

a plan is in place to redesign our plant and replace our outdated system with new equipment.

Time estimated that it will take to correct problem:

unknown as of yet, currently we are still waiting on the funds to begin construction

Sincerely,

Coy Dale

7-22-21

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NCR form 2