

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0020036 Discharge Number: 001-A

Facility: CITY OF MELBOURNE WWTP

Address: AR HWY 9 SPUR (CIRCLE DRIVE)

City: MELBOURNE State: AR Zip: 72556

Contact: Coy Delfe Phone: 870-291-7773

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
3/6/24	TRC INSTANTANEOUS MAX		0.06	0.011
3/27/24	TRC INSTANTANEOUS MAX		0.56	0.011

We feel this problem was due to:

The state of the wastewater plant makes it hard to adjust. ~~AND~~ AND our equipment is outdated and faulty.

We plan on correcting the problem in this manner:

We plan on having the entire wastewater system revamped.

Time estimated that it will take to correct problem:

We are in the process of getting our grants approved.

Sincerely,

Lucas Champ

4-26-24

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)