

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 NPDES Enforcement Section  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: NPDES Permit No: AR 0020036-001A Discharge Number: \_\_\_\_\_  
 Facility: City of Melbourne  
 Address: P O Box 800  
 City: Melbourne State: AR Zip: 72556  
 Contact: Coy Dale Phone: 870-368-4215

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May 2018	0.26			0.11
May 2018	1669	30 Day		200
May 2018	730	7 Day		400

We feel this problem was due to:

To much Chlorine and not enough sulfur dioxide  
Not enough Chlorine


We plan on correcting the problem in this manner:

with an updated waste water plant

Time estimated that it will take to correct problem:

Starting work on plant in December.

Sincerely,



Authorized Signature

6/27/18

Date

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

# REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING March 2018

PARAMETER VIOLATED	CI2 DAILY MAX						
--------------------	---------------	--	--	--	--	--	--

REPORTED VIOLATIONS	0.10						
---------------------	------	--	--	--	--	--	--

PARAMETER VIOLATED	0.011						
--------------------	-------	--	--	--	--	--	--

WEEK OF 3/28/2018

*Please fill out the following information*

CAUSE OF VIOLATION There was not enough Sulfur Dioxide to remove the Chlorine residual.

DURATION OF VIOLATION 2 days

CORRECTIVE ACTION turned down Chlorinator, The City is in the process of starting to update the waste water plant w/ ultra violet System and do away with Chlorine.

EXPECTED COMPLIANCE DATE \_\_\_\_\_

*Roy Dale*  
SIGNATURE / DATE

# REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING April 2018

PARAMETER VIOLATED	FECAL 30DA GEO	FECAL 7 DAY GEO	FECAL 7 DAY GEO					
REPORTED VIOLATIONS	910	777	1066					
PARAMETER VIOLATED	200	400	400					
WEEK OF		Apr 04 18	4/25/18					

*Please fill out the following information*

CAUSE OF VIOLATION There was not enough chlorine

DURATION OF VIOLATION 2 days

CORRECTIVE ACTION Turned up chlorine,

EXPECTED COMPLIANCE DATE \_\_\_\_\_


  
SIGNATURE / DATE

# City of Melbourne

63 Municipal Dr.  
P.O. Box 800  
Melbourne, AR 72556

LITTLE ROCK AR 722

27 JUN 2015 PM 2:1



ADEQ  
NPDES Enforcement Section  
5301 Northshore Dr.  
N. Little Rock, AR 72118

72118-531799

