

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0020036

Discharge Number: 001-A

Facility: CITY OF MELBOURNE WWTP

Address: AR HWY 9 SPUR (CIRCLE DRIVE)

City: MELBOURNE

State: AR

Zip: 72556

Contact: Coy Dale

Phone:

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/3/23	TRC INSTANTANEOUS MAX		0.5	0.011

We feel this problem was due to:

We feel the problem was due to the plant being old and hard to adjust the flow correctly. And it's hard to clean and maintain the plants.


We plan on correcting the problem in this manner:

We have a plan to revamp the waste water plant with new equipment and we will monitor levels carefully.

Time estimated that it will take to correct problem:

We already have everything in the works we are waiting on a grant for construction to begin.

Sincerely,



7-5-23

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)