

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0020036 Discharge Number: 001-A

Facility: CITY OF MELBOURNE WWTP

Address: AR HWY 9 SPUR (CIRCLE DRIVE)

City: MELBOURNE State: AR Zip: 72556

Contact: Coy Dale Phone: 870-291-7773

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11/8/23	TRC INSTANTANEOUS MAX		0.49	0.011
11/29/23	TRC INSTANTANEOUS MAX		0.74	0.011

We feel this problem was due to:

The state of the wastewater plant, and the equipment used to monitor it need replaced. They are hard to adjust and rotting away.

We plan on correcting the problem in this manner:

We are working with a new engineer to make plans on updating the plant.

Time estimated that it will take to correct problem:

As soon as our engineer gets everything sorted out we will have an estimated time we are trying to hurry the process along.

Sincerely,

Lucas Champ

12-20-23

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)