

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0020036

Discharge Number: 001-A

Facility: CITY OF MELBOURNE WWTP

Address: AR HWY 9 SPUR (CIRCLE DRIVE)

City: MELBOURNE

State: AR

Zip: 72556

Contact: Coy Date

Phone:

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10/4/23	TRC INSTANTANEOUS MAX		0.14	0.011
10/25/23	TRC INSTANTANEOUS MAX		0.09	0.011
OCTOBER	FECAL 30 DAY GEO		> 2000.0	1000.0
10/4/23	FECAL 7 DAY GEO		> 2000.0	2000.0

We feel this problem was due to:

The State of the waste water plant and it's ~~eq~~ equipment.

We plan on correcting the problem in this manner:

We plan on refurbishing the waste water plant and getting new ~~o~~ testing equipment.

Time estimated that it will take to correct problem:

We are in the process of switching engineering firms but are hoping to start soon.

Sincerely,

Lucas Champ

11-22-23

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)