

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0020036 Discharge Number: 001-A

Facility: CITY OF MELBOURNE WWTP

Address: AR HWY 9 SPUR (CIRCLE DRIVE)

City: MELBOURNE State: AR Zip: 72556


Contact: Coy Dale Phone: 870-291-7773

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
SEPTEMBER	TSS MONTHLY AVERAGE	< 58.53		51.0
SEPTEMBER	TSS MONTHLY AVERAGE		< 27.0	15.0
9/6/23	TSS 7 DAY AVERAGE		53.0	22.5
9/6/23	TRC INSTANTANEOUS MAX		0.17	0.011

We feel this problem was due to:
The state of the waste water plant makes it hard to adjust everything correctly.

We plan on correcting the problem in this manner:
Having the waste water plant redone and replacing faulty equipment.

Time estimated that it will take to correct problem:
We are in the process of switching engineering firms so we do not have a solid time frame yet

Sincerely,

Submitted By: _____ Date: 10-23-23

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)