

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0020036 Discharge Number: 001-A

Facility: CITY OF MELBOURNE WWTP

Address: AR HWY 9 SPUR (CIRCLE DRIVE)

City: MELBOURNE State: AR Zip: 72556

Contact: _____ Phone: _____


Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
AUGUST	FECAL 30 DAY GEO		1005.0	1000.0

We feel this problem was due to: The waste water plant is in need of some repairs it's hard to accurately adjust everything to meet parameters.

We plan on correcting the problem in this manner: We are working on getting the waste water plant ~~rest~~ updated and repaired. we are currently waiting for our funding to be finalized.

Time estimated that it will take to correct problem: As soon as the budget is ready we are going to have it revamped with new systems in place.

Sincerely,



10-21-22

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)