

# REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING April 2017

PARAMETER VIOLATED	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC MO AVG						
REPORTED VIOLATIONS	6.80	16.34						
PARAMETER VIOLATED	3.9	13.3						

WEEK OF Apr 26 17

*Please fill out the following information*

CAUSE OF VIOLATION heavy rainfall around this time along with some older sludge in ditch

DURATION OF VIOLATION April 2017

CORRECTIVE ACTION got septic sludge wasted out of ditch & researched the use of magnesium oxide to help with ammonia level

EXPECTED COMPLIANCE DATE May 2017

Dustin Payne 6-5-17  
SIGNATURE / DATE

taylor@adeq.state.nj.us