

REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE
PERMIT NUMBER AR0020036 A-01
PERIOD ENDING 4/30/2020

PARAMETER VIOLATED	Chlorine, total residual						
REPORTED VIOLATIONS	0.63						
PARAMETER VIOLATED	< 0.011						

WEEK OF 04/29/20


Please fill out the following information

CAUSE OF VIOLATION the cause of the violation was due to an equipment failure
at our wastewater plant

DURATION OF VIOLATION the equipment in question has been fixed however we are
continuing to have problems with the regulating equipment due to the equipment's age

CORRECTIVE ACTION the redesign & renovation of our wastewater plant
should take care of our current equipment ~~malfunctions~~ malfunctions

EXPECTED COMPLIANCE DATE renovation completion date is as of yet unknown



SIGNATURE / DATE