

REPORT OF NON COMPLIANCE

72556

MELBOURNE AR
41 CAMP RD
EUGENE BARSDALE

NAME OF FACILITY MELBOURNE, CITY OF

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING August 2018

PARAMETER VIOLATED	NITROGEN AMMONIA LDC MO AVG	NITROGEN AMMONIA CONC MO AVG	NITROGEN AMMONIA CONC 7 DAY AVG MAX	NITROGEN AMMONIA CONC 7 DAY AVG MAX	O3 DAILY MAX			
REPORTED VIOLATIONS	33.13	15.7	10.60	20.8	1.5			
PARAMETER VIOLATED	13.3	3.9	3.9	3.9	0.011			
WEEK OF			8/8/18	Aug 29 18	8/29/2018			

Please fill out the following information

CAUSE OF VIOLATION The violation was caused by problems occurring within our waste water plant. Corrections for these issues have been planned and we are doing our best until we can start repairs and rebuilding the plant

DURATION OF VIOLATION _____

CORRECTIVE ACTION We are planning a full redesign & reworking of our waste water plant starting in Dec 2018

EXPECTED COMPLIANCE DATE starting Dec 2018, estimated completion date as of yet unknown

Coe
SIGNATURE / DATE

REPORT OF NON COMPLIANCE

NAME OF FACILITY MELBOURNE, CITY OF
 PERMIT NUMBER AR020036 001-A
 PERIOD ENDING July 2018

PARAMETER VIOLATED	FECAL 30DA GEO	FECAL 7-DAY GEO						
REPORTED VIOLATIONS	421	627						
PARAMETER VIOLATED	200	400						
WEEK OF	7/6/18							


Please fill out the following information

CAUSE OF VIOLATION We we're in violation on such date because at waste water plant, we had a ~~star~~ Rotor break down and chlorine levels needed to be adjusted as well

DURATION OF VIOLATION 2 weeks

CORRECTIVE ACTION partially corrected by repairing our rotor and correcting our chlorine levels, and a more permanent correction by redesigning and updating our waste treatment plant starting in december 2018

EXPECTED COMPLIANCE DATE rotor repaired as of 9-14-18, redesign/update date: UA


 SIGNATURE / DATE