

REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE

PERMIT NUMBER AR0020036 A-001

PERIOD ENDING 8/31/2020

PARAMETER VIOLATED	Chlorine (total residual)	FECAL 30DA GEO					
REPORTED VIOLATIONS	1.70	1020.00					
PARAMETER VIOLATED	0.011	400.0					

WEEK OF 08/05/20 08/26/20

Please fill out the following information

CAUSE OF VIOLATION the problem occurred due to the regulation of our chemicals at the wastewater plant, we have had continuous problems out of our regulating equipment

DURATION OF VIOLATION the problem has been fixed however the redesign & reconstruction of our plant will be the permanent corrective action

CORRECTIVE ACTION a line to a regulator had become clogged, replacement of the lines is the corrective action, however the redesign of our wastewater plant will be the permanent corrective action

EXPECTED COMPLIANCE DATE unknown as of yet



 SIGNATURE / DATE