

REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE
PERMIT NUMBER AR0020036 001-A
PERIOD ENDING December 2019

PARAMETER VIOLATED	Chlorine total residual						
REPORTED VIOLATIONS	0.25						
PARAMETER VIOLATED	< 0.011						

WEEK OF 12/27/19

Please fill out the following information

CAUSE OF VIOLATION We are continuing to experience problems with our wastewater plant due to continued equipment failure

DURATION OF VIOLATION until the redesign and renovation of our plant can be completed

CORRECTIVE ACTION an overhaul & redesign of our entire wastewater plant system

EXPECTED COMPLIANCE DATE unknown as of this time



SIGNATURE / DATE