

REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE

PERMIT NUMBER AR0020036 001-A

PERIOD ENDING February 2020

PARAMETER VIOLATED	Chlorine, total residual						
REPORTED VIOLATIONS	0.52						
PARAMETER VIOLATED	< 0.011						

WEEK OF 12/27/19


Please fill out the following information

CAUSE OF VIOLATION We are continuing to experience problems with our wastewater plant and keeping the equipment regulating the plant.

DURATION OF VIOLATION we have fixed the current problem however the permanent solution will be the redesign of our plant

CORRECTIVE ACTION the redesign of our plant will change the system from chlorine + sulfur dioxide to UV.

EXPECTED COMPLIANCE DATE date of construction is as of yet unknown



SIGNATURE / DATE