

REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE

PERMIT NUMBER AR0020036 A-001

PERIOD ENDING 7/31/2020

PARAMETER VIOLATED	Chlorine, total residual						
REPORTED VIOLATIONS	0.43						
PARAMETER VIOLATED	0.011						

WEEK OF 07/29/20


Please fill out the following information

CAUSE OF VIOLATION We are continuing to experience equipment failures at our wastewater plant, the issue was caused by a bad line on our sulfur dioxide system

DURATION OF VIOLATION unknown, couldn't have been more than 48 hrs due to the maintenance schedule

CORRECTIVE ACTION replaced lines running to and from regulators

EXPECTED COMPLIANCE DATE original issue is fixed however the redesign of our plants equipment will begin as soon as possible



 SIGNATURE / DATE