

REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE

PERMIT NUMBER AR0020036 A-001

PERIOD ENDING 6/30/2020

PARAMETER VIOLATED	FECAL 7 DAY GEO						
REPORTED VIOLATIONS	564.00						
PARAMETER VIOLATED	400.00						

WEEK OF 06/24/20


Please fill out the following information

CAUSE OF VIOLATION We are continuing to experience issues with regulating our plant, our chlorination & dechlorination systems are both in poor condition due to the age of our plant

DURATION OF VIOLATION this problem has been fixed however the plant redesign will become the actual permanent repair

CORRECTIVE ACTION a redesign of our waste water plant will ultimately be the ~~repair~~ corrective action

EXPECTED COMPLIANCE DATE unknown as of yet (covid-19 has slowed the process drastically)


SIGNATURE / DATE