

REPORT OF NON COMPLIANCE

NAME OF FACILITY CITY OF MELBOURNE
PERMIT NUMBER AR0020036 001-A
PERIOD ENDING March 2019

PARAMETER VIOLATED	Chlorine, total residual	Chlorine, total residual						
REPORTED VIOLATIONS	0.59	0.06						
PARAMETER VIOLATED	0.011	0.011						
WEEK OF	3/6/19	3/27/19						

Please fill out the following information

CAUSE OF VIOLATION The violation occurred due to a malfunction with our sulfur dioxide injection into the system.

DURATION OF VIOLATION we are unable to determine a exact time frame for the violation

CORRECTIVE ACTION We have tried to adjust accordingly but a true permanent solution will occur when our wastewater plant redesign and reconstruction is complete.

EXPECTED COMPLIANCE DATE When we complete our wastewater plant we will be able to stay compliant.



SIGNATURE / DATE